

INLAND VALLEY DEVELOPMENT AGENCY

DFAS PAKING LOT IMPROVEMENTS

April 8, 2009

ADDENDUM NO. 2

This addendum which includes sheets 1 through 6 must be signed by the bidder's authorized representative and permanently attached to the signature page of the Bidder's Proposal (i.e. stapled) . Proposals submitted without Addendum or with an unsigned Addendum will be determined to be non-responsive and will be discarded.

The Addendum 1 is entirely superseded by the following information:

ITEM # 1. – Bid Item #4 Unclassified Excavation (Export) should be bid with equipment to knock-down the unloaded dirt at the export location. Export location is about 2 miles away from project site.

ITEM# 2. – Materials testing will be the responsibility of the Contractor. Engineer will have the right to oversee and request records from tests. All tests shall be filed in a binder to be submitted to Engineer at the completion of Project.

ITEM# 3. – Bid Item 2 – Storm Water Pollution Control to be bid and executed along the SWPPP documents attached in this Addendum and Item 24 of the Special Requirements.

ITEM# 4. – The Date and Time of Bid submittal is: April 15, 2009 - 2:00 p.m. PST

ITEM# 5. – The cutoff date and time for RFIs to Engineer regarding this bid will be April 10, 2009 – 12:00 p.m. PST at 294 S. Leland Norton Way, San Bernardino, CA 92408

ITEM# 6. – The RFIs received and answered:

1. Question : Section 15 – Aggregate Base calls out Crushed Aggregate Base while Bid Schedule calls out Class II. Which one?
Answer: Use Aggregate Base Class II.
2. Question: Should the Bidder present all detailed Insurance documents at bid level, waiver of subrogation, additional insured, etc.

DFAS Parking Lot Improvements

Addendum 2

Inland Valley Development Agency

Answer: Third paragraph of Notice Inviting Bids treats the issue. At bid time Proof of Coverage will suffice. After award the Contractor should present all insurance documents per contract requirements.

3. Question: Who will pay for Permits and Fees with City of San Bernardino

Answer: See Item # 9 of this Addendum

4. Question: What material testing will be required by the contractor? Compaction? Asphalt? Concrete? Can CMB be used instead of CAB for parking lot base? Due to the aggressive schedule can you add working days to complete the project? Submittal and approval process can take up the twenty (20) working days.

Answer: Material testing will be required for compaction and AC. Design requires Class AB. Project is scheduled for completion in the end of May.

ITEM# 7. – Bid Item 13 – 25' Wide Chain Link Gate "will be the relocation of the adjacent existing gate with power to it.

ITEM#8. – Bid Item 12 – 30" Wide Chain Link Gate" will be a new swinging gate.

ITEM# 9. – Permits and Fees – omitted page SR-8 The Permits and Fees will be paid by Owner. Contractor shall prepare application and submit to Owner's representative for payment.

ITEM# 10.- **The entire Bid Item Schedule in the bidding documents has been replaced with the following Bid Item Schedule**

DFAS Parking Lot Improvements
 Addendum 2
 Inland Valley Development Agency

Item	Pay Item	Unit	Estimate		Amount
			Quantity	Unit Price	
1.	Mobilization	LS	1	\$ _____	\$ _____
2.	Storm Water Pollution Control	LS	1	\$ _____	\$ _____
3.	Clearing and Grubbing	LS	1	\$ _____	\$ _____
4.	Unclassified Excavation (Export)	CY	12,850	\$ _____	\$ _____
5.	Asphalt Concrete	TON	2,500	\$ _____	\$ _____
6.	Aggregate Base (Class II)	TON	2,800	\$ _____	\$ _____
7.	6" P.C.C. Curb	LF	3,100	\$ _____	\$ _____
8.	P.C.C. Sidewalk	SF	3,505	\$ _____	\$ _____

DFAS Parking Lot Improvements
 Addendum 2
 Inland Valley Development Agency

Item	Pay Item	Unit	Estimate		Amount
			Quantity	Unit Price	
9.	P.C.C. Curb and Gutter	LF	1,042	\$ _____	\$ _____
10.	P.C.C. Cross Gutter	SF	991	\$ _____	\$ _____
11.	Relocate Fire Hydrant	EA	3	\$ _____	\$ _____
12.	30' Wide Chain Link Gate	EA	1	\$ _____	\$ _____
13.	25' Wide Chain Link Gate	EA	1	\$ _____	\$ _____
14.	Relocate Existing Chain Link Fence	LF	1,100	\$ _____	\$ _____
15.	Slurry Seal	TON	36	\$ _____	\$ _____
16.	Trash Enclosure	EA	1	\$ _____	\$ _____

DFAS Parking Lot Improvements
Addendum 2
Inland Valley Development Agency

Bid Delivery Address: 294 S. Leland Norton Way San Bernardino, CA 92408

Tel. 909-382-4100

By: _____

**Alex Estrada – Director of Redevelopment
and Transportation**

Date:

By: _____

Bidder's Authorized Representative

Date: