San Bernardino International Airport Authority (SBIAA)
294 S. Leland Norton Way
San Bernardino, CA 92408
(909) 382-4100

REQUEST FOR INFORMATION # 3

NOTICE INVITING BIDS
FOR THE CONSTRUCTION OF THE IRP SITE 2 LANDFILL PARKING LOT

August 26, 2009

Q1. Regarding the Instructions to Bidders, BD-4, Item No. 7, Completion of Bidder's Proposal (and Related Bidder's Documents) and Submission to Agency, refers to Bidding Documents BD-15 through BD-36, were there pages omitted from the Bidder's Documents?

A1. Yes. Attachment to RFI No.3 includes the 3-page form titled "Bidder's Statement of Experience." Please provide this form with your Bidder's Qualifications bid package/proposal.

Q2. On page SP-17, Section 2, A-2 indicates panels as *Brickcrete*, yet below item "a." *Cedarcrete*, which is correct?

A2. "Brickcrete" and "Cedarcrete" are referencing finish and color, these will be specified by the Airport at time of construction.

Q3. Also reference on SP-17, Section 2, item "a" what is meant by "6-20' " high?

A3. The specs were taken from the Manufacturers standards. The 6-20' range just represents the range of height that they are able to make. The wall shall be 8' tall as stated in the plans.

PLEASE NOTE: All RFIs and Addendums should be signed by the Bidder's authorized representative as indication of receipt and a copy included with Bid Proposal package to SBIAA.

Further, RFI questions and/or comments will not be accepted after 12:00pm, Friday, August 28, 2009.

Contractors signature Date