

INLAND VALLEY DEVELOPMENT AGENCY (IVDA)

REQUEST FOR INFORMATION (RFI) NO. 3

Parking Lot Infrastructure Improvements Project

Located around

Building 730 and Building 747

EDA Grant No. 07-49-06137

August 26, 2010

**Q1. Should there be a bid item for furnishing and installing the sod at building 747?**

A1. Yes, Bid Item 1009 SODDED TURF with an estimated quantity of 4275 SF should be added to Bid Schedule Ten - Landscaping and Irrigation (refer to Addendum No. 3).

**Q2. Is the quantity for Bid Item No. 1004 provide and install 24" box trees correct? The plans show 8 each palm trees at Bldg. 730 and 12 each palm trees at Bldg. 747.**

A2. The correct estimated quantity for Bid Item No. 1004 is 24" Box Trees is 20 EA (refer to Addendum No. 3).

**Q3. Where on the plans is bid item no. 1008? Is it the organic mulch around the shrubs shown in detail 'B' on sheet 40 of 43?**

A3. Bid Item No. 1008 "Bark Mulch (2" Depth)" is shown Sheet 40 of 43, Detail B "Shrub Planting", construction note 2. Yes, it is called out as 2" layer of organic Mulch

**Q4. Is there going to be a new bid schedule, that will show the items that have been deleted on the revised plans?**

A4. The revised bid schedule summary sheet (BD-24 Summary [revised]) has been issued as part of Addendum No. 2. Please refer to IVDA's website [www.sbdairport.com](http://www.sbdairport.com) to download sheet.

**Q5. Can you please clarify the work hours for this project?**

A5. Working hours are generally 8 hours for the work day. The start and end of day times should be per the selected Contractor's discretion and approved by IVDA. Please also refer to Special Requirements "Section 7 - Work Schedule" of the specifications.

**Q6. What are the cost of permits need for this project?**

A6. No permits are anticipated for this Project.

**Q7. Is there a detail for the canopy awning?**

A7. Standard details for canopy awning are provided in Appendix 3 of the Specifications.